



November 30, 2017

Addendum Number One Hwy65 Waterline Replacement Project #140391D

This Addendum to the Request for Bids for the above referenced project supersedes all contrary and conflicting information, which is hereby supplemented or revised in certain particulars as follows:

Questions from the Pre-Bid Meeting and answers are as follows:

- Q: Is the utility permit in-hand at the Town of Cedaredge for this project?
A: No. The CDOT utility permit is not in-hand and will be the responsibility of the contractor. The Town Engineer shall assist as necessary to pull this permit.
- Q: Is the 54" minimum cover depth required for trenchless replacement within the CDOT right-of-way?
A: No. CDOT waives cover depth requirements for in-place replacement. Open trench replacement must conform to cover depth CDOT requirements within the CDOT right-of-way.
- Q: Is the contractor responsible for traffic control?
A: Yes. The contractor is responsible for all traffic control, and protection of open pits, etc.

Attendees at the meeting were:

- Williams Construction
- United Companies
- DOWL
- Peterson Excavating Inc.
- Western Gravel Constructors
- Tribble & Sons Construction LLC
- Fletch's LLC
- Grand Junction Pipe
- RE Belden Construction and Directional Drilling
- Kissner C.C., Inc.
- Core and Main (HD Supply)
- Old Castle SWG – DBA Telluride Gravel
- Grand Junction Winwater
- Ridgway Valley Enterprises, Inc.
- Benson Brothers LLC

--- End of Addendum ---